

A Peer Reviewed Open Access International Journal

Standalone DC Micro Grids for a Three-variable Optimal Energy Management Strategy



R.Nitish Kumar M.Tech(EPS), Arjun College of Technology and Sciences, Batasingaram.

Abstract:

Due to substantial generation and demand fluctuations in standalone green microgrids, energy management strategies are becoming essential for the power sharing and voltage regulation purposes. The classical energy management strategies employ the maximum power point tracking (MPPT) algorithms and rely on batteries in case of possible excess or deficit of energy. In order to realize constant current-constant voltage (IU) charging regime and increase the life span of batteries, energy management strategies require being more flexible with the power curtailment feature. In this paper, a coordinated and multivariable energy management strategy is proposed that employs a wind turbine and a photovoltaic array of a standalone DC microgrid as controllable generators by adjusting the pitch angle and the switching duty cycles.

EXITING CONCEPT:

The stability of a dc microgrid is measured in terms of the stability of its dc bus voltage level which is one of the main control objectives. The grid voltage source converters (G-VSCs) are the primary slack terminals to regulate the voltage level of grid-connected microgrids. Battery banks, on the other hand, are effective slack terminals for standalone microgrids their energy absorbing capacities are limited regarding a number of operational constraints.



Rosaiah Mudigondla M.Tech(PEED), Assistant Professor, Arjun College of Technology and Sciences, Batasingaram. Proposed concept:

The proposed strategy is developed as an online nonlinear model predictive control (NMPC) algorithm. Applying to a sample standalone dc microgrid, the developed controller realizes the IU regime for charging the battery bank. The variable load demands are also shared accurately between generators in proportion to their ratings. The DC bus voltage is regulated within a predefined range, as a design parameter.

INTRODUCTION:

The microgrid may operate as an extension of the main grid, (grid-connected) or as a standalone grid with no connection to the grid. Standalone dc microgrids have some distinct applications automotive or marine industries, rural areas. Since ac systems suffer from the need of synchronization of several generators, dc microgrids are more efficient due to the fact that dc generators and storages do not need ac-dc converters for being connected to dc microgrids. The few issues regarding voltage regulation, power sharing, and battery management, is severe in standalone green micro grids that consist of only intermittent solar and wind energy sources, and lead to the necessity of more controllable strategies. The grid voltage source converters are the primary slack terminals to regulate the voltage level of grid-connected microgrids. Battery banks, on the other hand, are effective slack terminals for standalone microgrids.



A Peer Reviewed Open Access International Journal

Their energy absorbing capacities are limited regarding a number of operational constraints, as explained later in this section. In order to regulate the voltage level of standalone dc micro grids. Present load shedding strategies for the cases in which there is insufficient power generation or energy storage. Present strategies that curtail the renewable power generations of standalone dc micro grids if the battery bank cannot absorb the excess generation. These curtailment strategies restrict the batteries charging rate by the maximum absorbing power.Standalone dc microgrids are usually located in small-scale areas where the power sharing between DGs can be managed by centralized algorithms which are less affected by two issues:

a) Batteries in charging mode are nonlinear loads causing distortions to the grid voltage

b) The absolute voltage level of a standalone microgrid is shifted as the result of the load demand variation.

A number of phenomena affect the batteries operation during the charging mode [19]:

1) Applying high charging currents, the batteries voltages quickly reach to the gassing threshold.

2) The internal resistor and hence power losses and thermal effects increase at high SOC levels.

3) Batteries cannot be fully charged with a constant high charging current.

Operational constraint, the maximum absorbed power by the batteries in order to protect them from being overcharged. Therefore batteries act as nonlinear loads during the charging mode. Depending on the proportion of the power generation to the load demand ratio within standalone DC microgrids, three cases are possible.

1) Power generation and load demand are balanced;

2) Load demand exceeds power generation causes dc bus voltage to drop in absence of any load shedding; and

3) Power generation is higher than load demand leads batteries to be overcharged and bus voltage to climb.

Energy management strategy (EMS) is proposed, as its control objectives, three aforementioned issues corresponding standalone dc micro grids; i.e., dc bus voltage regulation, proportional power sharing, and battery management. In contrast to the strategies available in literature in which renewable energy systems (RESs) always operate in their MPPT mode, the proposed multivariable strategy uses a wind turbine and a PV array as controllable generators and curtails their generations if it is necessary. The proposed EMS is developed as an online novel NMPC strategy that continuously solves an optimal control problem (OCP) and finds the optimum values of the pitch angle and three switching duty cycles.

It simultaneously controls four variables of micro grids:

- 1) Power coefficient of the wind turbine.
- 2) Angular velocity of the wind generator.
- 3) Operating voltage of the PV array and
- 4) Charging current of the battery bank.

It is shown that, employing new available nonlinear optimization techniques and tools, the computational time to solve the resulting NMPC strategy is in permissible range. The proposed strategy implements the IU charging regime that helps to increase the batteries life span.

Block diagram:





May 2016

Volume No: 3 (2016), Issue No: 5 (May) www.ijmetmr.com



A Peer Reviewed Open Access International Journal

DESCRIPTIONS:

The standalone dc microgrid in above figure is a smallscale microgrid for remote applications. The wind turbine operates at variable speeds and is connected to the electrical generator directly, that is, the direct-drive coupling. The variable speed operation is more flexible for the power management and MPPT applications. Furthermore, direct-drive coupling is more efficient and reliable and is more popular for small-scale wind turbines. In spite of high cost, permanent magnet synchronous generators (PMSGs) are the most dominant type of direct-drive generators in the market, chiefly due to higher efficiency.

MODELING:



Fig2. Modified version of the system model

The authors in [20] presented a mathematical model of standalone green dc microgrids as hybrid differential algebraic equations (hybrid DAEs). Fig. 2 summarizes a modified version of the proposed model in [20]. Since this paper focuses on the case in which there is an excess power greater than or equal to the maximum possible absorbing rate of the battery bank, the hybrid nature of the battery bank operation is ignored for the sake of simplicity. The differential and algebraic states, i.e., and , and the manipulated and non-manipulated control variables, namely, and , are detailed later throughout the next sub-sections. In what follows, the following notations are used to model the standalone dc microgrid in Fig. 1 as DAEs:

$$\mathcal{F}(\mathbf{x}, \dot{\mathbf{x}}, \mathbf{z}, \mathbf{u}, \mathbf{v}) = \begin{bmatrix} f_1(\mathbf{x}, \dot{\mathbf{x}}, \mathbf{z}, \mathbf{u}, \mathbf{v}) \\ f_2(\mathbf{x}, \dot{\mathbf{x}}, \mathbf{z}, \mathbf{u}, \mathbf{v}) \\ \vdots \\ f_{24}(\mathbf{x}, \dot{\mathbf{x}}, \mathbf{z}, \mathbf{u}, \mathbf{v}) \end{bmatrix} = 0$$
(1)

The first two constraints f1 and f2 are due to the fact that in standalone dc microgrids the sum of the generated, stored, and consumed powers is always zero:

$$f_1 = V_{dc} \Big(I_{pvdc} + I_{wtdc} + I_{batdc} - I_{load} \Big), \qquad (2a)$$

$$f_2 = V_{dc} - I_{load} R_L. \qquad (2b)$$

Modeling of the Three System:

- A. Wind Branch.
- B. Battery Branch.
- C. Solar Branch.
- A. Wind Branch

Performance of the wind turbines is measured as the power coefficient curve with respect to the tip speed ratio and pitch angle. Equation (3) shows the power coefficient curve of three-blade wind turbines:

$$f_{3} = C_{p,norm} - \frac{1}{C_{p,\max}} \times (C_{1}(\frac{C_{2}}{\lambda_{i}} - C_{3}\beta - C_{4})\exp(-\frac{C_{5}}{\lambda_{i}}) + C_{6}\lambda), \quad (3a)$$

$$f_4 = \lambda - \frac{Rad \times \omega_r}{U_x},\tag{3b}$$

$$f_5 = \lambda_i - \left(\frac{1}{\lambda + 0.08\beta} - \frac{0.035}{\beta^3 + 1}\right)^{-1},\tag{3c}$$

Where gamma and bita, respectively, are the tip speed ratio and pitch angle. Rad is the radius of the blades and Cp,max is the maximum achievable power coefficient at the optimum tip speed ratio of gamma out.

Equation (4) presents the connected PMSG generator:

$$f_6 = \frac{\mathrm{d}\omega_r}{\mathrm{d}t}(t) - \frac{1}{J}(T_e - T_m - F\omega_r), \tag{4a}$$

$$f_7 = -T_e \times \omega_r - I_{wtdc} \times V_{dc}, \tag{4b}$$

$$f_8 = -T_m \times \omega_r - (C_{p,norm} (\frac{U_x}{U_{x,base}})^3 P_{nom}.$$
 (4c)

May 2016



A Peer Reviewed Open Access International Journal

Energy management strategies of microgrids must estimate the dc bus voltage level deviation from its set point in about every 5–10 s. It means that except the angular velocity of the generator (4a) all other fast voltage and current dynamics can be ignored.

For energy management strategies, the average model of the buck converter is replaced with the steady-state equations for the continuous conduction mode (CCM)

$$f_9 = V_{dc} - D_w V_{wt}, \tag{5a}$$

$$f_{10} = I_{wt} - D_w I_{wtdc} \tag{5b}$$

whereDw is the switching duty cycle of the converter and all remaining parameters are as depicted in Fig. 1. The average dc output voltage of the rectifier, Vwt, in presence of the non-instantaneous current commutation is calculated as follows.

$$V_{wt} = 1.35 V_{LL} - \frac{3}{\pi} \omega_e L_s I_{wt} \tag{6}$$

$$f_{11} = I_{wtdc} - \frac{\pi}{3P\omega_r L_s D_w} \left\{ \frac{1.35\sqrt{3}P\psi\omega_r}{\sqrt{2}} - \frac{V_{dc}}{D_w} \right\}.$$
 (7)

B. Battery Branch:

Charging operation of a lead acid battery bank, consisting of (Nbatp*Nbats) batteries, is modeled as:

$$f_{12} = \frac{V_{bstack}}{N_{bats}} - V_0 + R_{bat} \frac{I_{bstack}}{N_{batp}} + \frac{P_1 C_{\max}}{C_{\max} - Q_{act}} Q_{act} + \frac{P_1 C_{\max}}{Q_{act} + 0.1 C_{\max}} I_f, \quad (8a)$$

$$f_{13} = \frac{\mathrm{d}Q_{act}}{\mathrm{d}Q_{act}}(t) - \frac{1}{1 - 1} \frac{I_{bstack}(t)}{\mathrm{d}Q_{act}}, \quad (8b)$$

$$dt = \frac{dI_f}{dt}(t) + \frac{1}{T}(I_f - \frac{I_{bstack}}{N_{t-1}}),$$
(8c)

$$f_{15} = V_{bstack} - \frac{V_{dc}}{1 - D_L},$$
(8d)

$$f_{16} = I_{bstack} - (1 - D_b)I_{batdc}, \tag{8e}$$

$$f_{17} = SOC - \left\{ 1 - \frac{Q_{act}}{C_{\max}} \right\}$$
(8f)

the voltage, current, and state of charge of the battery bank. If is the filtered value of the battery current with the time constant of Ts and Qact is the actual battery capacity. The experimental parameter P1 requires being identified for each type of battery while the maximum amount of the battery capacity, *Cmax*, internal resistor of battery, *Rbat*, and the battery constant voltage, *V0*, are given by manufacturers. By ignoring the discharging mode of the battery bank operation, the bi-directional converter acts as a boost-type converter [(8d)–(8e)].

C. Solar Branch:

The equivalent electrical circuit of the PV module [27], [28] is used to mathematically model the solar branch, consisting of a PV array and a boost converter [29]. Eq. (9) shows the characteristic equations of a PV array, consisting Npvp*Npvs of PV modules:

$$f_{18} = I_{pv} - I_{ph} + I_0 \left\{ \exp\left(\frac{V_{pv} + \frac{N_{pvs}}{N_{pvp}} R_s I_{pv}}{n_d N_s} \frac{q \times N_{pvs}}{K T_c}\right) - 1 \right\} + \frac{V_{pv} + \frac{N_{pvs}}{N_{pvp}} R_s I_{pv}}{\frac{N_{pvs}}{N_{pvp}} R_s h},$$

$$f_{19} = I_{ph} - N_{pvp} \times \left(R_s + R_{sh}\right) - S$$
(9a)

$$\begin{pmatrix} \frac{R_s + R_{sh}}{R_{sh}} I_{sc,stc} + k_I \left(T_c - T_{c,stc}\right) \end{pmatrix} \frac{S}{S_{stc}}, \quad (9b)$$

$$f_{20} = I_0 - N_{pvp} \times \frac{I_{sc,stc} + k_I \left(T_c - T_{c,stc}\right)}{\exp\left(\frac{V_{oc,stc} + k_V \left(T_c - T_{c,stc}\right)}{n_d N_s} \frac{q}{KT_c}\right) - 1}$$

$$(9c)$$

Where Iph denotes the photocurrent and I0 is the diode reverse saturation current. *Rs* and *Rsh*, respectively, are the series and parallel equivalent resistors of each PV module and all other parameters are as follows:

electron charge $(1.60218 \times 10^{-19});$ q KBoltzman constant $(1.38066 \times 10^{-23});$ N_s number of the PV cells in series as the PV module (-); T_c current amount of the PV cell temperature (K); short-circuit current of the PV module at standard $I_{sc,stc}$ test condition (STC) (A); k_I temperature coefficient of the short-circuit current $(A/^{\circ}C);$ k_V temperature coefficient of the open-circuit voltage $(V/^{\circ}C);$ Scurrent amount of the solar irradiance (W/m^2) ; S_{stc} amount of the solar irradiance at the STC (W/m^2) ; $T_{c,stc}$ amount of the cell temperature at the STC (K); open-circuit voltage of the PV module at the STC $V_{oc,stc}$ (V).



A Peer Reviewed Open Access International Journal

Similar tothe wind branch, the average model of the boost converter is replaced with the steady-state equations for CCM

$$f_{21} = V_{pv} - (1 - D_s)V_{dc}, \tag{10a}$$

$$f_{22} = I_{pvdc} - (1 - D_s)I_{pv}.$$
 (10b)

CONTROLLER DESIGN:

Optimal Control Problems (OCPs)

OCPs, as (11), make explicit use of the system model, given by (11b), in order to find an optimal control law $u^*(.)$, which meets number of equality and inequality constraints. The term optimal here is defined with respect to a certain criterion that implies the control objectives. This criterion is specified with a cost functional *J*, consisting of the Lagrangian term lambda and the terminal cost term *M*. While the Lagrangian term indicates the cost function during the period of time , the terminal cost penalizes final values. Equations (11d) and (11e), respectively, formulate the final and initial constraints which must be maintained by the optimal solution. Moreover, (11g) represents boxing constraints on the states and control variables:

$$\begin{split} u^*(.) &= \underset{\mathbf{u}(.) \in \Re^n}{\operatorname{arg minimize}} \quad J(\mathbf{x}(t), \mathbf{z}(t), \mathbf{u}(t), T) := \\ &\int_t^{t+T} \mathcal{L}(\mathbf{x}(\tau), \mathbf{z}(\tau), \mathbf{u}(\tau)) d\tau + \mathcal{M}(\mathbf{x}(T), \mathbf{z}(T)) \quad (11a) \\ &\text{ s.t.: } \mathcal{F}(\mathbf{x}(t), \dot{\mathbf{x}}(\tau), \mathbf{z}(\tau), \mathbf{u}(\tau), \mathbf{v}(\tau)) = 0 \quad (11b) \\ & \mathcal{H}(\mathbf{x}(\tau), \mathbf{z}(\tau), \mathbf{u}(\tau)) \leq 0 \quad (11c) \\ & \mathcal{R}(\mathbf{x}(T), \mathbf{z}(T)) = 0 \quad (11d) \\ & \mathbf{x}(\tau) = \mathbf{x}_0, \mathbf{z}(\tau) = \mathbf{z}_0 \quad (11e) \\ & \forall \tau \in [t, t+T] \quad (11f) \\ & \mathbf{x}(\tau) \in \mathcal{X}, \mathbf{z}(\tau) \in \mathcal{Z}, \mathbf{u}(\tau) \in \mathcal{U}. \quad (11g) \end{split}$$

Nonlinear Model Predictive Control (NMPC):

OCPs are open-loop strategies and are wrapped by a feedback loop to construct NMPC strategies [30]. NMPC strategies, which are also called as the receding horizon control, continuously solve an OCP over a finite-horizon T using the measurements obtained at t as the initial values. Then the first optimal value is applied as the next control signal.

Comparing with the conventional methods, NMPCs are inherently nonlinear and multivariable strategies that handle constraints and delays.

There are three different techniques to discretize and solve OCPs:

1) Dynamic programming method based on the Bellman's optimality principle.

2) Indirect method based on the Pontryagin minimum principle.

3) Direct methods that convert OCPs into nonlinear optimization problems (NLPs) which are then solved by NLP solvers.

Control System:

Since it focuses on the charging mode of the battery operation, The proposed EMS successively gets the estimated system states, , as inputs and calculates the optimal solution, , as outputs. The external state estimator and the predictor of the non-manipulated variables are out of the scope of this paper. step ahead predictions of the solar irradiance, wind speeds, and demands are extracted either from load а meteorological center or an external predictor using autoregressive-moving-average (ARMA) technique [37]. The bus voltage level of the microgrid, , is set externally and hence the developed controller can act as the secondary and primary levels of the hierarchical architecture [13].

The developed NMPC controller consists of three entities:

1) The dynamic optimizer that successively solves OCP at each sampling time h,

2) The mathematical model of the system to predict its behavior

3) The cost function and constraints of the relevant OCP.

The optimal pitch angle is applied as a set point to an inner closed-loop controller. Moreover, the optimal values of the switching duty cycles are applied to the



A Peer Reviewed Open Access International Journal

pulse width modulators (PWMs) of the dc-dc converters.

1) Control Objectives:

() () 1)

Three aforementioned control objectives, i.e., dc bus voltage regulation, proportional power sharing, and implementing the IU regime to charge batteries, are formulated by two slack variables in (12) and (13) and the cost function in (14)

$$f_{23} = \alpha_1 - (V_{dc} - \overline{V}_{dc}).$$
(12)

$$f_{24} = \alpha_2 - \left\{ \frac{I_{wtdc}V_{dc}}{P_{wt,nom}} \left(\frac{U_{x,base}}{\max(U_x, U_{x,base})} \right)^3 - \frac{I_{pvdc}V_{dc}}{P_{pv,nom}} \frac{S_{x,base}}{\max(S_x, S_{x,base})} \right\}.$$
 (13)

$$J(\mathbf{x}(n), \mathbf{z}(n), \mathbf{u}(n), N) := \sum_{k=n}^{n+N} \left\{ \beta_1 \left\| \frac{1}{\overline{I}_c} \left(\frac{I_{bstack}(k)}{N_{batp}} - \overline{I}_c \right) \right\|_2 + \beta_2 \left\| \frac{V_{dc}(k) - \overline{V}_{dc}}{\overline{V}_{dc}} \right\|_2 \right\} + \left\{ \beta_1 \left\| \frac{1}{\overline{I}_c} \left(\frac{I_{bstack}(N)}{N_{batp}} - \overline{I}_c \right) \right\|_2 + \beta_2 \left\| \frac{V_{dc}(N) - \overline{V}_{dc}}{\overline{V}_{dc}} \right\|_2 \right\},$$

$$(14a)$$

$$\begin{split} J(\mathbf{x}(n), \mathbf{z}(n), \mathbf{u}(n), N) &:= \\ \sum_{k=n}^{n+N} \left\{ \beta_3 \left\| \frac{V_{bstack}(k) - N_{bats}V_{gas}}{N_{bats}V_{gas}} \right\|_2 + \beta_4 \left\| \frac{V_{dc}(k) - \overline{V}_{dc}}{\overline{V}_{dc}} \right\|_2 \right\} \\ &+ \left\{ \beta_3 \left\| \frac{V_{bstack}(N) - N_{bats}V_{gas}}{N_{bats}V_{gas}} \right\|_2 + \beta_4 \left\| \frac{V_{dc}(N) - \overline{V}_{dc}}{\overline{V}_{dc}} \right\|_2 \right\}. \end{split}$$

$$(14b)$$

2) Box Constraints:

Equation (15) adds the pitch angle control feature to the developed EMS in order to limit the produced aerodynamic power by the wind turbine:

$$0 \le -T_e \omega_r \le P_{wt,nom}.\tag{15}$$

The other box constraints on the manipulated variables and the system states are formulated as follows:

TABLE I: DESIGN PARAMETERS AND THECOMPUTATIONALTIMEOFTHEDEVELOPED NMPC CONTROLLER

Parameter Name	Parameter Value
Prediction horizon T (sec)	10
Sampling time h (sec)	5.0
No. of the discretization samples N	2
$\overline{V}_{dc}(V)$	48.0
Average Computational Time (sec)	2.066
Minimum Computational Time (sec)	0.628
Maximum Computational Time (sec)	3.565

TABLE II:WIND TURBINE, PMSG, BATTERY STACK, AND PV PARAMETERS IN THIS STUDY

Wind turbine	Wind turbine PMSG		Battery stack		PV array		
$C_1(-)$	0.517	$J(Kg.m^2)$	0.35	$C_{max}(Ah)$	48.15	$R_s(\Omega)$	0.221
$C_2(-)$	116.0	F(N.m.s)	0.002	$R_{bat}(\Omega)$	0.019	$R_{sh}(\Omega)$	405.4
$C_{3}(-)$	0.4	P(-)	8	$V_0(V)$	12.3024	$n_d(-)$	1.3
$C_4(-)$	5.0	$\psi(V.s)$	0.8	$P_1(-)$	0.9	$N_s(-)$	54
$C_5(-)$	21.0	$P_{rated}(KW)$	10.0	$N_{bats}(-)$	8	$I_{sc,stc}(A)$	8.21
$C_{6}(-)$	0.007	$L_s(H)$	0.0083	$N_{batp}(-)$	3	$V_{oc,stc}(V)$	32.9
$\lambda_{opt}(-)$	8.1			$T_s(sec)$	0.726	$k_I(A/K)$	0.003
$P_{wt,nom}(KW)$	10.0			$V_{bstack,nom}(V)$	96.0	$k_V(V/K)$	-0.12
Rad (m)	4.01			$P_{bat,nom}(KW)$	1.296	$N_{pvs}(-)$	1
$U_{x,base}(m/s)$	12.0			$C_{10}(Ah)$	45.0	$N_{pvp}(-)$	10
$C_{p,max}(-)$	0.48			$V_{gas}(V)$	13.0	$P_{pv,nom}(KW)$	2.001

EXPERIMENTAL RESULTS:

Simulation circuit design in Matlab:







Volume No: 3 (2016), Issue No: 5 (May) www.ijmetmr.com May 2016



A Peer Reviewed Open Access International Journal







Fig shown: Output wave forms of the simulation

CONCLUSION AND FUTURE WORKS:

In this paper, we developed a novel optimal EMS that manages the energy flows across a standalone green dc microgrid, consisting of the wind, solar, and battery branches. A coordinated and multivariable online NMPC strategy has been developed to address, as the optimal EMS, three main control objectives of standalone dc microgrids. These objectives are the voltage level regulation, proportional power sharing, and battery management. In order to address these objectives, the developed EMS simultaneously controls the pitch angle of the wind turbine and the switching duty cycles of three dcdc converters. It has been shown that the developed controller tracks the MPPs of the wind and solar branches within the normal conditions and curtails their generations during the underload conditions.

REFERENCES:

[1] J. M. Guerrero, M. Chandorkar, T. Lee, and P. C. Loh, "Advanced Control Architectures for Intelligent Microgrids-Part I: Decentralized and Hierarchical Control," IEEE Trans. Ind. Electron., vol. 60, no. 4, pp. 1254–1262, 2013.

[2] R. S. Balog, W. W. Weaver, and P. T. Krein, "The load as an energy asset in a distributed DC smartgrid architecture," IEEE Trans. Smart Grid, vol. 3, no. 1, pp. 253–260, 2012.

[3] J. M. Guerrero, P. C. Loh, T. L. Lee, and M. Chandorkar, "Advanced Control Architectures for Intelligent Microgrids-Part II: Power quality, energy storage, and AC/DC microgrids," IEEE Trans. Ind. Electron., vol. 60, no. 4, pp. 1263–1270, 2013.

[4] N. Eghtedarpour and E. Farjah, "Control strategy for distributed integration of photovoltaic and energy storage systems in DC micro-grids," Renew. Energy, vol. 45, no. 0, pp. 96–110, 2012.

[5] D. Chen and L. Xu, "Autonomous DC voltage control of a DC microgrid with multiple slack terminals," IEEE Trans. Power Syst., vol. 27, no. 4, pp. 1897–1905, Nov. 2012.

[6] L. Xu and D. Chen, "Control and operation of a DC microgrid with variable generation and energy storage," IEEE Trans. Power Del., vol. 26, no. 4, pp. 2513–2522, Oct. 2011.

[7] S. Anand, B. G. Fernandes, and M. Guerrero, "Distributed control to ensure proportional load sharing and improve voltage regulation in low-voltage DC microgrids," IEEE Trans. Power Electro., vol. 28, no. 4, pp. 1900–1913, 2013.

Volume No: 3 (2016), Issue No: 5 (May) www.ijmetmr.com



A Peer Reviewed Open Access International Journal

[8] B. Zhao, X. Zhang, J. Chen, C. Wang, and L. Guo, "Operation optimization of standalone microgrids considering lifetime characteristics of battery energy storage system," IEEE Trans. Sustain.Energy, to be published.

[9] T. Zhou and B. Francois, "Energy management and power control of a hybrid active wind generator for distributed power generation and grid integration," IEEE Trans. Ind. Electron., vol. 58, no. 1, pp. 95–104, 2011.

[10] X. Liu, P. Wang, and P. C. Loh, "A hybrid AC/DC microgrid and its coordination control," IEEE Trans. Smart Grid, vol. 2, no. 2, pp. 278–286, 2011.

[11] H. Kanchev, D. Lu, F. Colas, V. Lazarov, and B. Francois, "Energy management and operational planning of a microgrid with a PV-based active gen. for smart grid applications," IEEE Trans. Ind. Electron., vol. 58, no. 10, pp. 4583–4592, 2011.

[12] H. Ghoddami, M. B. Delghavi, and A. Yazdani, "An integrated windphotovoltaic-battery system with reduced power-electronic interface and fast control for grid-tied and off-grid applications," Renew. Energy, vol. 45, no. 0, pp. 128–137, 2012.

[13] J. M. Guerrero, J. C. Vasquez, J. Matas, L. G. de Vicua, and M. Castilla, "Hierarchical control of droopcontrolled AC and DC microgrids-a general approach toward standardization," IEEE Trans. Ind. Electron., vol. 58, no. 1, pp. 158–172, 2011.

[14] P. H. Divshali, A. Alimardani, S. H. Hosseinian, and M. Abedi, "Decentralized cooperative control strategy of microsources for stabilizing autonomous VSC-Based microgrids," IEEE Trans. Power Syst., vol. 27, no. 4, pp. 1949–1959, Nov. 2012.