

Power Quality Improvement for grid Connected wind driven Induction Generator By using STATCOM based control scheme

Y.Vijaya

M.Tech Scholar
JB Institute of Engineering &
Technology (UGC autonomous),
Hyderabad, India.

T.S.Sastry

Associate Professor
JB Institute of Engineering &
Technology (UGC autonomous),
Hyderabad, India.

Dr. S. Siva Prasad

Head of the Department
JB Institute of Engineering &
Technology (UGC autonomous),
Hyderabad, India.

Abstract:

Renewable energy sources, which are expected to be a promising alternative energy source, can bring new challenges when connected to the power grid. Like conventional power plants, wind power plants must provide the power quality required to ensure the stability & reliability of the power system. While connecting wind driven induction generator to grid it is important to understand source of disturbance that affect the power quality. In general voltage & frequency must be kept as stable as possible.

This stability can be obtained by using FACTS devices. Recently voltage-source or current-source inverter based various FACTS devices have been used for flexible power flow control, secure loading and damping of power system oscillation. In this paper a STATCOM based controller scheme is developed to improve the power quality. Simulations using MATLAB / SIMULINK are carried out to verify the performance of the proposed controller.

Keywords:

Power quality, Wind power, distribution network, induction generator, STATCOM, reactive power, harmonics.

I.INTRODUCTION:

To have sustainable growth and social progress, it is necessary to meet the energy need by utilizing the renewable energy resources like wind, biomass, hydro, co-generation, etc. In sustainable energy system, energy conservation and the use of renewable source are the key paradigm.

The need to integrate the renewable energy like wind energy into power system is to make it possible to minimize the environmental impact on conventional plant [1]. The integration of wind energy into existing power system presents technical challenges and that requires consideration of voltage regulation, stability, power quality problems.

The power quality is an essential customer-focused measure and is greatly affected by the operation of a distribution and transmission network. The issue of power quality is of great importance to the wind turbine [2]. There has been an extensive growth and quick development in the exploitation of wind energy in recent years. The individual units can be of large capacity up to 2 MW, feeding into distribution network, particularly with customers connected in close proximity [3].

Today, more than 28000 wind generating turbines are successfully operating all over the world. In the fixed-speed wind turbine operation, all the fluctuation in the wind speed are transmitted as fluctuations in the mechanical torque, electrical power on the grid and leads to large voltage fluctuations. The power quality issues can be viewed with respect to the wind generation, transmission and distribution network, such as voltage sag, swells, flickers, harmonics etc. However the wind generator introduces disturbances into the distribution network.

Fig.1. Grid connected system for power quality improvement. One of the simple methods of running a wind generating system is to use the induction generator connected directly to the grid system. The induction generator has inherent advantages of cost effectiveness and robustness




Fig.1. Grid connected system for power quality improvement.

However; induction generators require reactive power for magnetization. When the generated active power of an induction generator is varied due to wind, absorbed reactive power and terminal voltage of an induction generator can be significantly affected. A proper control scheme in wind energy generation system is required under normal operating condition to allow the proper control over the active power production.

In the event of increasing grid disturbance, a battery energy storage system for wind energy generating system is generally required to compensate the fluctuation generated by wind turbine. A non-linear load on a power system is typically a rectifier (such as used in a power supply), or some kind of arc discharge device such as a fluorescent lamp, electric welding machine, or arc furnace. Because current in these systems is interrupted by a switching action, the current contains frequency components that are multiples of the power system frequency.

It changes the shape of the current waveform from a sine wave to some other form and also create harmonic currents in addition to the original (fundamental frequency) AC current. The most used unit to compensate for reactive power in the power systems are either synchronous condensers or shunt capacitors, the latter either with mechanical switches or with thyristor switch, as in Static VAR Compensator (SVC). The disadvantage of using shunt Capacitor is that the reactive power supplied is proportional to the square of the voltage.

Consequently, the reactive power supplied from the capacitors decreases rapidly when the voltage decreases [3]. To overcome the above disadvantages; STATCOM is best suited for reactive power compensation and harmonic reduction. It is based on a controllable voltage source converter (VSC).

II. STATIC SYNCHRONOUS COMPENSATOR (STATCOM):

The STATCOM is a shunt-connected reactive-power compensation device that is capable of generating and/or absorbing reactive power and in which the output can be varied to control the specific parameters of an electric power system. It is in general a solid-state switching converter capable of generating or absorbing independently controllable real and reactive power at its output terminals when it is fed from an energy source or energy-storage device at its input terminals.

Specifically, the STATCOM, which is a voltage-source converter which when fed from a given input of dc voltage, produces a set of 3-phase ac-output voltages, each in phase with and coupled to the corresponding ac system voltage through a relatively small reactance (which is provided by either an interface reactor or the leakage inductance of a coupling transformer). The dc voltage is provided by an energy-storage capacitor.

A STATCOM based control technology has been proposed for improving the power quality which can technically manages the power level associates with the commercial wind turbines. A STATCOM can improve power-system performance like:

1. The dynamic voltage control in transmission and distribution systems.
2. The power-oscillation damping in power- transmission systems.
3. The transient stability.
4. The voltage flicker control; and
5. The control of not only reactive power but also (if needed) active power in the connected line, requiring a dc energy source.

A STATCOM is analogous to an ideal synchronous machine, which generates a balanced set of three sinusoidal voltages at the fundamental frequency with controllable amplitude and phase angle.

This ideal machine has no inertia, is practically instantaneous, does not significantly alter the existing system impedance, and can internally generate reactive (both Capacitive and inductive) power.

III. WIND DRIVEN INDUCTION GENERATOR WITH STATCOM:

The STATCOM is a three-phase voltage source inverter having a capacitor connected to its DC link. Fig 2 shows a neutral clamped topology of VSI for STATCOM application.




Fig 2. Six Pulse VSI STATCOM:

But in the proposed system with STATCOM, reactive power requirement of induction generator and load is supplied by the STATCOM instead of grid. The STATCOM injects a compensating current of variable magnitude and frequency component at the PCC [8]-[10].

The shunt connected STATCOM is connected to the PCC through interfacing inductors. The induction generator and load is also connected to the PCC [13]. The STATCOM compensator output is controlled, so as to maintain the power quality norms in the grid system.

IV. REFERENCE CURRENT GENERATION FOR STATCOM:

Reference current for the STATCOM is generated based on instantaneous reactive power theory [7]-[10]. A STATCOM injects the compensation current which is a sum of reactive component current of IG, non-linear load and harmonic component current of non-linear load. Pq theory gives a generalized definition of instantaneous reactive power, which is valid for sinusoidal or non sinusoidal, balanced or unbalanced, three-phase power systems with or without zero sequence currents and/or voltages.




Fig .3 Three phase power system.

Fig.3 shows the three phase power system, instantaneous Voltages, v_a, v_b, v_c in volts and instantaneous currents, i_a, i_b, i_c in amps of a three phase system are expressed as instantaneous space vectors 'v' and 'i' given by (1)

$$V = \begin{pmatrix} v_a \\ v_b \\ v_c \end{pmatrix} \quad i = \begin{pmatrix} i_a \\ i_b \\ i_c \end{pmatrix} \quad (1)$$

'p' is the instantaneous active power of a three-phase circuit in Watts, given by (2)

$$p = v \times i \quad (2)$$

Instantaneous active power of a three-phase circuit 'p' is the scalar product of instantaneous voltage and current. It is the product of the sum of three phase voltages and current, given by (3)

$$P = V_a I_a + V_b I_b + V_c I_c \quad (3)$$

Instantaneous active power consists of average component and oscillatory component as given by (4)

$$P = P_{dc} + P_{ac} \quad (4)$$

'P_{dc}' is the average component of instantaneous active power in watts and 'P_{ac}' is the oscillatory component of instantaneous active power in watts. 'q' is the instantaneous reactive power of a three-phase circuit in VAR, given by

$$q = \|\mathbf{v} \times \mathbf{i}\| \quad (5)$$

Instantaneous reactive power of a three-phase circuit 'q' is the vector product of instantaneous voltage and current, given by (6)

$$\mathbf{q} = \begin{pmatrix} q_a \\ q_b \\ q_c \end{pmatrix} = \begin{pmatrix} |v_b i_c - v_c i_b| \\ |v_c i_a - v_a i_c| \\ |v_a i_b - v_b i_a| \end{pmatrix} \quad (6)$$

Total current is the sum of instantaneous active, reactive and harmonic component of current given by (7)

$$\mathbf{i} = \mathbf{i}_p + \mathbf{i}_q + \mathbf{i}_h \quad (7)$$

'i_p', 'i_q' and 'i_h' are of instantaneous active, reactive and harmonic component of current respectively. 'i_p' is the instantaneous active component current in amps given by (8)

$$i_p = \frac{P_{dc} \cdot v}{v_a^2 + v_b^2 + v_c^2} \quad (8)$$

Since it is a non linear load reactive component and harmonic component current are used as a reference current for STATCOM. The reference current for the three phases as given by (9),(10),(11).

$$i_{a^*} = i_{ap} - i_{as} = i_{aq} + i_{ah} \quad (9)$$

$$i_{b^*} = i_{bp} - i_{bs} = i_{bq} + i_{bh} \quad (10)$$

$$i_{c^*} = i_{cp} - i_{cs} = i_{cq} + i_{ch} \quad (11)$$

'i_{a*}', 'i_{b*}' and 'i_{c*}' are the STATCOM reference current of three phases respectively. 'i_{ap*}', 'i_{bp*}' and 'i_{cp*}' are fundamental active component current of three phases respectively.

Similarly 'i_{as*}', 'i_{bs*}' and 'i_{cs*}' are the STATCOM source current of three phases respectively. 'i_{aq}', 'i_{bq}' and 'i_{cq}' are the sum of instantaneous reactive component current of induction generator and load of three phases respectively. 'i_{aq}', 'i_{bq}' and 'i_{cq}' are the instantaneous harmonic component current load of three phases respectively.

V. HYSTERESIS CONTROLLER:




Fig.4. Hysteresis current Modulation.

The current control scheme for STATCOM is using 'hysteresis current controller' as shown in fig.4. Using this the controller keeps the STATCOM current between boundaries of hysteresis area and correct switching signals for STATCOM operation [11]-[12].

With the hysteresis control, limit bands are set on either side of a signal representing the desired output waveform [6]. The inverter switches are operated as the generated signals within limits.

The control circuit generates the sine reference signal wave of desired magnitude and frequency, and it is compared with the actual signal. As the signal exceeds a prescribed hysteresis band, the upper switch in the half bridge is turned OFF and the lower switch is turned ON.

As the signal crosses the lower limit, the lower switch is turned OFF and the upper switch is turned ON. The actual signal wave is thus forced to track the sine reference wave within the hysteresis band limits.

VI. MATLAB MODELEING AND SIMULATION RESULTS:

The induction generators are widely used, due to the advantage of cost effectiveness, robustness, ruggedness, simplicity and requirement of no brush and commutators. Fig.5. Shows the simulink diagram of STATCOM controlled grid.

Here the load is diode based non-linear load. Induction generator is connected to the grid. The power, which is generated by the wind based induction generator is connected to the grid. Statcom is connected to the grid to reduce the harmonics and to improve the power factor.

Voltage source converter is connected through a three phase breaker to grid. Statcom is operated for after 0.1sec.




Fig.5 STATCOM based IG and non-linear load

Single phase wave forms:




Fig.6.output waveform of a 1 phase source current and load currents.

Fig.6. shows the output waveforms of with and without STATCOM controlled grid. wave forms of source and load currents when statcom is in off condition from (0 – 0.1)sec after the 0.1sec time statcom is in operating condition. During with statcom operation the source and load currents are having less harmonics.

Three phase waveforms:




Fig.7.output waveforms of 3-ph source current and load current

Fig 7.shows the output waveforms of a 3 phase source and load current. wave forms of source and load currents when statcom is in off condition from (0 – 0.1)sec after the 0.1sec time statcom is in operating condition. During with statcom operation the source and load currents are having less harmonics.




Fig.8.FFT Analysis of source current without statcom

Fig.8. shows the FFT analysis of source current without statcom. Before compensation the source current is having the value of Total Harmonic Distortion (THD) is 27.61%.The source current contains more harmonics .




Fig.9.FFT Analysis source current with statcom.

Fig.9. shows the FFT analysis of source current with statcom. After compensation the source current is having the value of Total Harmonic Distortion (THD) is 3.12%.The source current contains less amount harmonics .By using the statcom technique the THD value is reduced to 3.12% from 27.61%.




Fig.10.power factor with and without STATCOM

Fig.10. shows the power factor with and without STATCOM. Without statcom the the power factor is not unity ,after using STATCOM the power factor is improved to unity.The source current is in-phase with the reference sine wave.

VII. CONCLUSION:

This paper presents the STATCOM-based control scheme for power quality improvement in grid connected wind generating system feeding non linear load. The control system for the STATCOM is simulated using MATLAB/SIMULINK.The simulation results are shown in fig.6 for after compensation and before compensation.

Also the shape of the grid current is almost sinusoidal and the THD has been improved from 27.7 % to 3.1 % after compensation. It is found that the proposed control scheme has improved the power quality requirement of a low voltage grid connected wind driven IG system feeding a non-linear load.

REFERENCES:

[1] J. o .Q.Tande 'Applying Power Quality Characteristics of wind turbine for Assessing impact on Voltage Quality', Wind Energy, pp 52, 2002.

- [2] Z. Chen, E. Spooner, 'Grid Power Quality with Variable Speed Wind Turbines', IEEE Trans on Energy Conversion, Vol. 16, No. 2, pp 148- 154, June 2001.
- [3] L. H. Hansen, L. Helle, F. Blaabjerg, E. Ritchie, S. Munk-Nielsen, H. Binder, P. Sorensen and B. Bak - Jensen "Conceptual Survey of Generators and Power Electronics for Wind Turbines ", Riso National Laboratory, Roskilde, Denmark, December 2001.
- [4] A.Arulampalam, M.Bames & N.Jenkins, Power quality and stability improvement of a wind farm using ST A TCOM, Proc. TEE Generation, Transmission & Distribution, Vol. 153, No.6, 2006, 701-710.
- [5] Z.Saad-Saoud, M.1.Lisboa, 1.B.Ekanayake, N. Jenkins & G.Strbac, Application of ST A TCOMs to wind farms, Proc. TEE Generation, Transmission & Distribution, Vol. 145, No. 5, 1998, 511-516.
- [6] A.Arulampalam, 1.B.Ekanayake & N.Jenkins, Application study of a ST A TCOM with energy storage, Proc. IEE Generation, Transmission & Distribution, Vol. 150, No. 3, 2003, 373-384.
- [7] Fang Zheng Peng, Jih-Sheng Lai, 'Generalized Instantaneous Reactive Power Theory for Three-phase Power Systems', IEEE on instrumentation and measurement, vol. 45, no. 1, Feb,1996.
- [8] Joao Afonso, Carlos Couto, Julio Martins, 'Active Filters with Control Based on the p-q Theory', IEEE industrial electronic society newsletter. vol. 47, n° 3, Sept. 2000, ISSN: 0746-1240, pp. 5-10.
- [9] Fang Zheng Peng, George W. Ott, Jr., and Donald J. Adams, ' Harmonic and Reactive Power Compensation Based on the Generalized Instantaneous Reactive Power Theory for Three-Phase Four-Wire Systems' IEEE Trans on power electronics, vol. 13, no. 6, nov 1998.
- [10] Leszek S. Czarnecki: 'Instantaneous Reactive Power p-q Theory and Power Properties of Three-Phase Systems' IEEE Trans on power delivery', vol. 21, no. 1, Jan 2006.
- [11] K. Derradji Belloum, and A. Moussi, 'A Fixed Band Hysteresis Current Controller for Voltage Source AC Chopper' World Academy of Science, Engineering and Technology 452008.
- [12] 1. Dalessandro, U. Drofenik, S D. Round and 1.W. Kolar, 'A Novel Hysteresis Current Control for Three-Phase Three-Level PWM Rectifiers', Swiss Federal Institute of Technology (ETH) Zurich, Power Electronic Systems Laboratory.
- [13] D. Dragomir, N. Golovanov, P. Postolache, C. Toader, 'The connection to the grid of wind turbines'.